



# UNIVERSITY OF RUHUNA

## Faculty of Engineering

End-Semester 6 Examination in Engineering: November 2017

Module Number: CE6304

Module Name: Environmental Engineering Design

[Three Hours]

[Answer all questions, questions carry unequal marks, the distribution of marks within a question is indicated at the end of each part]

Q1. a) "In designing a carbon oxidation combined complete nitrification followed by denitrification process, the addition of a carbon source externally is not necessary while it is a must in the separate-stage denitrification process." Rationalize this statement highlighting the need of carbon for the denitrification process.

[2.0 Marks]

b) A primary-treated effluent is to undergo treatment by a separate stage carbon oxidation and nitrification system, in which two activated-sludge processes (ASPs) are to be designed to achieve a carbon oxidation and a complete nitrification, respectively. This system is followed by an anaerobic filter, granular gravity filter and granular activated carbon (GAC) adsorption process in order to be suitable for reuse. The nitrified effluent from the ASP enters the anaerobic filter for denitrification. Denitrified wastewater will be fed to the GAC adsorption process via a granular gravity filter in order to remove the remaining dissolved organic matter. Fixed-bed contactors filled with GAC and connected in parallel are used for the adsorption process. Table Q1(b) gives the design data of the ASPs and fixed-bed GAC contactors. Assume that the influent flow rate to the denitrification process, granular gravity filter and the GAC adsorption process are the same. Following equations are applicable for both carbon oxidation and nitrification processes:

$$(1/SRT) = YU - k_d; U = kS/(K + S); k = \mu_m/Y; 1/SRT^M \sim Yk - k_d;$$

$$SRT = SF(SRT^M); P_x = QY(S_0 - S)/(1 + k_d \cdot SRT)$$

Oxygen requirement for carbon oxidation,  $[M][T]^{-1} = Q(S_0 - S)/f - 1.42P_x$

The oxygen required for nitrification is 4.3 mg O<sub>2</sub>/mg ammonium nitrogen,  $[M][T]^{-1}$

Effluent flow rate (Q<sub>e</sub>) = Q - Q<sub>w</sub>

N = Effluent NH<sub>4</sub><sup>+</sup>-N concentration,  $[M] [L]^{-3}$

U = Specific substrate utilization rate,  $[T]^{-1}$

k = Maximum rate of substrate utilization,  $[T]^{-1}$

P<sub>x</sub> = Net mass of volatile solids (biological solids) produced,  $[M] [T]^{-1}$

SRT = Solids Retention Time,  $[T]^{-1}$

SRT<sup>M</sup> = Minimum Solids Retention Time,  $[T]^{-1}$

The GAC contactor is described by the Langmuir isotherm,  $\frac{x}{m} = \frac{0.002C_e}{1 - 0.29C_e}$ ;

Where,

x/m = Amount adsorbate adsorbed per unit weight of adsorbent,  $[M]/[M]$

C<sub>e</sub> = Equilibrium concentration of the adsorbate in the solution after adsorption,  $[M][L^{-3}]$

Note: When the unit of ' $C_e$ ' is ' $g/m^3$ '; the unit of ' $(x/m)$ ' is ' $mg/mg$ '  
 The following equation may also be used:

$$\left(\frac{x}{m}\right)_b = \frac{X_b}{M_c} = Q \left( C_i - \frac{C_b}{2} \right) \frac{t_b}{M_c}$$

$(x/m)_b$  = Field breakthrough adsorption capacity,  $[M]/[M]$

$C_b$  = Breakthrough adsorbate concentration in the effluent,  $[M]/[L^3]$

$C_i$  = Influent adsorbate concentration,  $[M]/[L^3]$

$M_c$  = Mass of GAC in the column,  $[M]$

$X_b$  = Mass of adsorbate adsorbed onto the GAC column at breakthrough,  $[M]$

Table Q1(b) Design information.

Description	Unit	Value
<b>Primary Clarifier and ASP</b>		
Flow rate of the primary clarified effluent ( $Q$ )	$m^3/d$	6,500
Total suspended solids (TSS) concentration in the influent of the primary clarifier	$g/m^3$	400
TSS removal efficiency of the primary clarifier	%	55
Soluble 5-d Biochemical Oxygen Demand ( $sBOD_5$ ) in primary clarified effluent	$g/m^3$	325
Ammonium Nitrogen ( $NH_4^+-N$ ) concentration in primary clarified effluent	$g/m^3$	65
Required effluent $sBOD_5$ of ASP for carbon oxidation	$g/m^3$	20
Design SRT of ASP for carbon oxidation	$d$	4.5
Concentration of microorganisms ( $X$ ) as volatile suspended solids (VSS)		
with respect to carbon oxidation	$g/m^3$	2,500
with respect to nitrification	$g/m^3$	175
Endogenous decay coefficient ( $k_d$ )		
with respect to carbon oxidation	$d^{-1}$	0.08
with respect to nitrification	$d^{-1}$	0.05
Yield coefficient ( $Y$ ) for microorganisms		
with respect to carbon oxidation	-	0.42
with respect to nitrification	-	0.22
$f$ {Conversion factor from $BOD_L$ (Ultimate $BOD$ ) to $BOD_5$ }	-	0.7
Maximum growth rate considering pH, dissolved oxygen (DO) and temperature ( $\mu'_m$ ) for nitrification	$d^{-1}$	0.45
SF (Safety Factor) for SRT for nitrification	-	3.25
Half velocity constant ( $K$ ) for $NH_4^+-N$	$g/m^3$	0.8
Flow rate of the waste sludge disposal line ( $Q_w$ )		
For ASP for carbon oxidation	$m^3/d$	250
For ASP for nitrification	$m^3/d$	200
<b>Fixed-bed GAC contactor</b>		
Influent soluble chemical oxygen demand ( $sCOD$ )	$g/m^3$	9.6
Breakthrough $sCOD$	$g/m^3$	2.5
No. of GAC contactors in parallel	-	10
Ratio of theoretical to breakthrough adsorption capacity	-	1: 0.25
Time to breakthrough ( $t_b$ )	$d$	50

- (i) Explain briefly the above treatment system qualitatively (i.e., target wastewater parameters and treatment mechanism of each unit process) [3.0 Marks]
- (ii) Determine the volume of each aerated reactor and the total oxygen requirement for both carbon oxidation and nitrification, and the effluent flow rates of each ASP. Assume that ammonia ( $NH_3$ ) does not undergo any reaction in the ASP for carbon oxidation. [6.0 Marks]
- (iii) Determine the amount of activated carbon that would be required for the polishing process of the remaining dissolved organic matter in terms of sCOD. [4.0 Marks]
- c) At sludge treatment of the treatment train described in Q1(b), the primary and activated excess sludge (biological solids) are mixed together, thickened in a gravity thickener, and digested anaerobically in a batch digester. Assume that two third of the biological solids produced by each ASP is wasted every day, and directed to the sludge treatment train.
- Following equation is applicable:  $V = \frac{(V_1+V_2)}{2} t_1 + V_2 t_2$ ; where  $V_1$ = Raw sludge loading rate,  $[L]^3[T]^{-1}$ ;  $V_2$ =Digested sludge accumulation rate,  $[L]^3[T]^{-1}$   
 Assume that the supernatant in the thickener is free of suspended solids.

Table Q1(c) gives the additional design information.

Table Q1(c) Additional design information for the sludge treatment train.

Description	Unit	Value
Density of sludge	kg/m <sup>3</sup>	1000
<b>Primary sludge</b>		
Content of solids in the primary sludge	%	4.5
<b>Activated sludge</b>		
Content of solids in the activated sludge (biological solids)	%	0.8
<b>Thickened sludge</b>		
Content of solids in the thickened sludge	%	5.5
<b>Batch anaerobic digester</b>		
Non-biodegradable organic matter fraction in the influent	%	35
Inert matter content of the influent	%	30
Digestion period( $t_1$ )	d	30
Digested sludge storage period( $t_2$ )	d	125
Solid content in the digested sludge	%	5.25

- (i) Determine the solids load onto the digester. [2.0 Marks]
- (ii) Determine the percent sludge volume reduction by the thickener. [5.0Marks]
- (iii) If the whole biodegradable portion of the organic matter is subjected to anaerobic digestion, determine the digester volume. [4.0 Marks]

(Q2) A primary treated municipal wastewater is to be further processed using a staged RBC system followed by a rapid infiltration (RI) system. The RBC is designed having a tapered feed flow for each stage. The RBC effluent will be applied in a cycle of flooding followed by drying to maximize the nitrification in the RI system. Table Q2 gives the design information.

The soluble 5-day biochemical oxygen demand ( $sBOD_5$ ) in each stage ( $S_n$ ) of RBC is given by the following equation:

$$S_n = \frac{-1 + \sqrt{1 + (4)(0.00974)(A_s/Q)S_{(n-1)}}}{(2)(0.00974)(A_s/Q)}; \text{ where } A_s = \text{total disk surface area on stage 'n';}$$

$Q = \text{Flow rate on stage 'n'; The units for 'S', 'A_s' and 'Q' are } g/m^3, m^2 \text{ and } m^3/d, \text{ respectively.}$

Table Q2 Design criteria of the staged RBC and RI systems.

Description	Unit	Value
<b>RBC system</b>		
Flow rate ( $Q$ )	$m^3/d$	2,250
Soluble 5-d Biochemical Oxygen Demand ( $sBOD_5$ ) in the primary effluent	$g/m^3$	550
No. of stages of the RBC system	-	3
Standard disk density	$m^2/shaft$	9,300
Maximum organic loading ( $sBOD_5$ ) on 1 <sup>st</sup> stage for secondary treatment	$g/m^2.d$	20
<b>RI system</b>		
Total $BOD_5$ of the RBC effluent	$g/m^3$	50
Application factor ( $F$ ) in calculating the annual hydraulic loading rate	-	0.1
Infiltration rate	$cm/h$	4.0
RI system operating period per year	$d$	250
Application(flooding) period of effluent per operating cycle	$d$	2
Drying period per operating cycle	$d$	6

- a) Determine the number of RBC shafts for the stage 1. [1.5 Marks]
- b) If the number of shafts at 2<sup>nd</sup> and 3<sup>rd</sup> stages decrease by 3 and 2 units, respectively, draw a schematic flow diagram of the RBC system. Assume the flow is parallel to the shaft. [1.5 Marks]
- c) What is the  $sBOD_5$  content in the RBC effluent? [2.0 Marks]
- d) Determine the following for the RI system:
  - (i) The annual average hydraulic loading rate ( $L_w$ ),
  - (ii) The annual average  $BOD_5$  loading rate,
  - (iii) The average application rate of the influent ( $R_a$ ),
  - (iv) The infiltration area requirement, and
  - (v) The average  $BOD_5$  loading rate over an 8  $d$  cycle.[0.5+0.5+0.5+0.75+0.75 Marks]

Q3. A wastewater treatment train employing a waste stabilization pond (WSP) system consists of 2 anaerobic ponds, 2 facultative ponds and a maturation pond. Two anaerobic ponds

are connected in parallel, and a facultative pond is connected to each anaerobic pond in series. The effluents from the 2 facultative ponds are connected to the maturation pond in series. Table Q3 shows the design information.

Table Q3 Design information.

Description	Unit	Value
Net evaporation rate ( $e$ )	mm/d	5
<b>Anaerobic pond</b>		
Influent wastewater flow rate	$m^3/d$	6,000
Influent 5-d Biochemical Oxygen Demand ( $BOD_5$ )	$g/m^3$	400
Design volumetric loading rate for $BOD_5$	$g/m^3.d$	300
Minimum allowable hydraulic retention time ( $HRT$ )	$d$	1
Depth	$m$	4
$BOD_5$ removal efficiency	%	75
<b>Facultative pond</b>		
Design surface loading rate for $BOD_5$	$kg/ha.d$	350
Minimum allowable $HRT$	$d$	4
Depth	$m$	1.5
$BOD_5$ removal efficiency	%	60
<b>Maturation pond</b>		
Design $HRT$	$d$	4.0
Depth	$m$	1.6
$BOD_5$ removal efficiency	%	70

Following equations are applicable for facultative and maturation ponds:

$$HRT = 2Ad / (2Q_i - Ae)$$

$$Q_e = Q_i - Ae$$

Where, A = Surface area of the pond,  $[L]^2$ ;  $Q_i$  = Influent flow rate,  $[L]^3/[T]$ ;

$Q_e$  = Effluent flow rate,  $[L]^3/[T]$ ;  $d$  = Depth of the pond,  $[L]$ ,  $e$  = Net evaporation rate,  $[L]/[T]$

Calculate the following:

- The volume and area requirements for the anaerobic pond, [3.0 Marks]
- The area requirement and the effluent flow rate of the facultative pond, [4.0 Marks]
- The area requirement and the effluent flow rate of the maturation pond, and [4.0 Marks]
- Effluent  $BOD_5$  of the maturation pond. [1.0 Marks]

Q4. An on-site wastewater management system consists of a septic tank, sub-surface flow constructed wetland system (CWS) and trench-type soil absorption field for a housing scheme. The septage is to be delivered to a small wastewater treatment plant (WWTP). Table Q3 shows the design information.

Assume the following:

The wastewater infiltrates into the vadoze zone of soil only through side walls of the trench; The average septage volume delivered daily at the said WWTP is equal to the volume of the septic tank excluding the free board; The delivery of septage will be done daily.

Table Q3 Design information of the on-site wastewater management system.

Description	Unit	Value
<b>Septic tank with two compartments</b>		
Average flow rate	$m^3/d$	3.5
Effluent 5-d Biochemical Oxygen Demand ( $BOD_5$ ) value	$g/m^3$	325
Liquid depth of the septic tank	$m$	1.0
Width of the septic tank	$m$	0.75
Height of the free board	$m$	0.5
Ratio of the lengths of 1 <sup>st</sup> compartment and the second compartment	-	2:1
<b>Sub-surface flow CWS</b>		
Required effluent $BOD_5$ ( $C_e$ )	$g/m^3$	30
1 <sup>st</sup> order reaction rate constant ( $K_T$ ) at 30 °C	$d^{-1}$	1.4
Design basin depth ( $d$ )	$m$	0.4
Basin slope ( $S$ )	-	0.02
Hydraulic conductivity ( $k_s$ )	$m^3/m^2.d$	420.0
Porosity of basin medium ( $\alpha$ )	-	0.35
Allowable hydraulic loading rates	$m^3/ha.d$	27.4 - 825.0
Allowable $BOD_5$ loading rates	$g/m^2.d$	7.1-11.4
<b>Trench-type soil absorption field</b>		
Maximum depth of the trench below the distribution pipe	$m$	1.25
Allowable hydraulic loading rate for the disposal field	$L/m^2.d$	20
Average wastewater flow rate to the small WWTP	$m^3/d$	7,500
$BOD_5$ value in influent to small WWTP	$g/m^3$	300
$BOD_5$ value in the septage	$g/m^3$	9,000

The following equations are applicable for the septic tank:

$$V_s = t_s \cdot Q$$

Where,  $V_s$  = volume required for settling, [ $L^3$ ]

$Q$  = average daily flow of wastewater, [ $L^3/T$ ]

$t_s$  (The time required for settling in days) =  $(1.5 - 0.3 \cdot \log Q)$ , ( $> 0.2d$ ), [T]

$V_d$  (The volume required for sludge digestion) =  $q_s \cdot t_d \cdot p$ , [ $L^3$ ]

$q_s$  (The volume of fresh sludge per person) =  $0.001 m^3/capita \cdot d$

$t_d$  (The time required for sludge digestion) =  $33 d$  (for an ambient temperature of  $30^\circ C$ )

$p$  (The population equivalent) =  $Q / (0.2 m^3/capita \cdot d)$

$V_{st}$  (The volume required for sludge storage) =  $r \cdot p \cdot n$

$n$  (desludging interval) = 2 years

$r$  (The volume of digested sludge per person per year) =  $0.04 m^3$

The volume required for scum storage =  $0.5 V_{st}$

The following equations are applicable for the sub-surface flow CWS:

$$(C_e/C_0) = \exp(-K_T t'); t' = (LW\alpha d)/Q; A_c = Q/k_s S$$

Where  $C_0$  = Influent  $BOD_5$ ,  $[M]/[L]^3$ ;  $L$  = Length of the basin,  $[L]$ ;  $W$  = Width of the basin,  $[L]$ ;  
 $t'$  = Pore-space detention time,  $[T]$

- a) Calculate the working capacity of the septic tank with two compartments, and thereby the total volume of the septic tank including the free board. [3.0 Marks]
- b) Draw the plan and front elevational views of the septic tank. [3.0 Marks]
- c) Verify whether the given design values of the sub-surface flow CWS (with 1 basin) agree with the allowable loading rates. If not, state the next step of the design procedure. [4.0 Marks]
- d) Calculate the required length of the disposal trench. [2.0 Marks]
- e) What will be the daily average influent  $BOD_5$  value at the small WWTP after mixing with the septage. [2.0 Marks]