



UNIVERSITY OF RUHUNA

Faculty of Engineering

End-Semester 6 Examination in Engineering: November 2017

Module Number: CE6251

Module Name: Building Services Engineering

[Three Hours]

[Answer all questions, each question carries twelve marks]

-
- Q1. a) Efficient means of movement inside buildings are very essential to achieve the intended purpose of the building. Discuss means of movement that can be used in different types of buildings. [3.0 Marks]
- b) A company has been awarded to design a lift system for a hotel complex having 25 storeys. Ground floor is proposed to be used as a Vehicle Park. The first 14 storeys are proposed to function as 3- star or less hotels while other above 10 storeys are to function as 4 and 5- star hotels. Consider each floor has 20 rooms on average. As the service engineer of that company you are asked to undertake this job. Design a suitable lift system for this hotel complex allowing zoning arrangement if required. Your answer should contain the number of lifts, the size of a lift and shaft and the capacity of a lift. Use the information given in Data Sheets 1, 2 and 3. Floor to floor height is 3.6 m. Any assumption made should be clearly mentioned and justified [6.0 Marks]
- c) Explain the consideration of following factors when integrating the service of a building
- Size of plants and equipment
 - Weight of equipment
 - Emission of exhaust gas from equipment
- [3.0 Marks]
- Q2. a) What are the factors that you have to consider when designing a pipe network to supply hot or cold water to a building? [2.0 Marks]
- b) Explain the terms, equivalent pipe length and effective pipe length. [2.0 Marks]
- c) Consider the following project description for a three-storey building which is proposed to be used as a students' hostel. Each floor contains separate toilets and bathrooms. It is proposed that main distribution pipe from the overhead tank is located centrally outside the building. From the main distribution pipe two branch pipes at either side are served at each floor. One branch pipe consists of four water closets, 4 wash basins and 3 showers. Showers are considered as having high peak demands. The distance to the remote appliance in each floor and each side is 10 m. Floor to floor height is 4 m and every appliance is located 1 m above the floor level.

- i Draw a schematic diagram of the proposed pipe network.
 - ii Determine the diameters of main distribution pipe and two branch pipes at 2nd floor. PVC pipes are to be used for the entire pipe network. Information given in Data Sheets 4 and 5 can be used when answering the question.
- [8.0 Marks]

- Q3. a) Describe the factors you should consider during the design phase to ensure fire precaution of a building.
- [2.0 Marks]
- b) As protection against fire, what are the advantages of providing proper means of escape?
- [2.0 Marks]
- c) "As a fire protection mean, Sprinkler system is more effective compared to other means like Risers, Extinguishers, Hose reels etc." Do you agree with this statement? Give reasons to support your answer.
- [2.0 Marks]
- d) You are required to design an automatic sprinkler system for a two-storey commercial building. The ground floor of the building is proposed to be used as departmental stores while the top floor is to be used as restaurants. Inside the building, the dimensions are 60 m x 40 m. The distribution pipe has to be arranged such a way that it is parallel to the long side of the building and range pipe are arranged only to a one direction from the distribution pipe. Design a suitable sprinkler system. You may assume that there are no obstructions like columns and beams inside the building. Use the information given in Data Sheet 6 when answering.
- [4.0 Marks]
- e) To ensure the efficiency of a sprinkler system, what are the factors you should consider when supplying water for the system?
- [2.0 Marks]

Q4.

- a) Discuss natural means that can be incorporated during the designing phase to minimize the thermal gain in a building.
- [3.0 Marks]
- b) Assume that you are required to prepare the budget to provide an Air conditioning system to an office consisting following facilities.
- 8 number of computers (25 watts each)
 - 15 number of office staff
 - 1 number of photocopy machine(10 watts)
 - 4 number of florescent lamps (15 watts each)

Other than the office staff it is expected to have minimum 5 customers inside the office at office working hours. The maximum allocation for this service requirement is limited to Rs 250,000.00. This allocation includes the installation charger of Rs. 7000.00 per A/C machine. The market prices for Air conditioning machines with different capacities are as follows.

9000 BTU A/C machine	Rs. 72,900.00
10000 BTU A/C machine	Rs. 85,500.00
12000BTU A/C machine	Rs. 95,500.00
18000BTU A/C machine	Rs. 139,900.00
24000BTU A/C machine	Rs. 174,900.00
36000BTU A/C machine	Rs. 205,500.00

The layout of the office is shown in Figure Q4. Opening dimensions of the office are 3.0 m × 1.5 m for W1 and 2.5m × 1.5 m for W2. It is in the ground floor of a two storey building. The upper floor is also used as offices with air conditioning.

Decide suitable Air conditioning arrangement to satisfy with the requirements and the budget. Use the Data Sheet 7 for your calculation and attach it to the answer booklet. All the assumptions you make should be clearly mentioned. The outside temperature is 32°C.

[9.0 Marks]

- Q5. a) What are the material properties and design aspects that should be ensured in choosing sanitary appliances?
[3.0 Marks]
- b) Explain the situations where we use single stack system and fully ventilated one pipe system.
[3.0 Marks]
- c) Loss of water seal in traps create unpleasant and unhygienic situation. Analyse this statement.
[3.0 Marks]
- d) Discuss the techniques that can be applied for waste separation in chutes.
[3.0 Marks]




Figure Q4: Floor plan of the office room to be Air Conditioned

Data Sheet 1


Elevator Speeds for Various Occupancies

Travel Distance		Offices and Hotels		Retail Stores		Apartments	
<i>ft</i>	<i>m</i>	<i>fpm</i>	<i>m/s</i>	<i>fpm</i>	<i>m/s</i>	<i>fpm</i>	<i>m/s</i>
0-60	0-20	200-400	1-2	200	1	100	0.5
60-120	20-36	300-400	1.5-2	200-300	1-1.5	200	1
120-240	36-72	500-600	2.5-3	200-400	1-2	200-400	1-2
240-500	72-150	800-1000	4-5				

fpm: feet per minute


Design Parameters for Elevators

Building type	Population Density		% Population Handled in 5 minutes	Average Interval Seconds
	<i>ft</i> ² /person	<i>m</i> ² /person		
Offices				
Prestige, single tenant	300	12	12-17	25-30
Investment downtown	100-110	9-10	12-14	30-35
Investment suburban	90-100	8-9	12-14	30-45
Apartment				
Prestige	1.5 per bedroom		5-7	50-70
Midrange	2 per bedroom		6-8	60-80
Low rental	2-3 per bedroom		6-8	80-120
Hotels				
4-5 star	1.5-2 per room		12-15	40-60
3 and less star	1.5-2 per room		10-12	50-70



Additional time to be added to the round-trip time when a car operates express through the lower floors of a building. The additional time is calculated as twice the distance divided by the speed, and therefore allows for both the up and down travel through the express zone at rated car speed.

Data Sheet 2









The five-minute handling capacity of sets of various sized elevator cars, plotted against the interval between them. First determine the required handling capacity of the group. Enter the graph from the left, and continue across to find the intersection of an acceptable car size and interval. If the required capacity is too high for an acceptable solution, try zoning. If it is too low, then the building is less than optimum size for elevating. Once a size and interval is determined, refer to Fig. 25.7.2 to determine the round-trip time of cars of various speeds. The number of cars required in the group is the round-trip time divided by the required interval.


Approximate Sizes and ratings of Elevator Cars

Capacity		Passengers		Inside W x D		Shaft W x D	
lb	kg	Max	Average	in	mm	in	Mm
2000	900	12	10	68 x 51	1700 x 1300	89 x 83	2200 x 2100
2500	1150	16	13	82 x 51	2100 x 1300	102 x 83	2550 x 2100
3000	1350	20	16	82 x 55	2100 x 1400	102 x 88	2550 x 2200
3500	1600	24	19	82 x 66	2100 x 1650	102 x 96	2550 x 2400
4000	1800	28	22	92 x 66	2300 x 1650	114 x 96	2850 x 2400

Data Sheet 3



The round trip time, and five-minute carrying capacity, for single elevator cars from 8 to 28 passenger nameplate capacity, and speeds from 100 to 800 fpm (0.5 to 4 m/s). All upper floors are assumed to have equal attraction. Figures are based on up peak conditions. Assumptions made about door operations and landing dwell times are intended to reflect good conditions. Slight to moderate downgrading is likely with nonstandard conditions such as extended door-open times and narrow or deep car shape.





Data Sheet 4

Loading units		Minimum flow rate with high peak demand	
	Loading unit rating	Type of appliances	Rate of flow (l/s)
Dwellings and flats			
W.C. flushing cistern	2	W.C. flushing cistern	0.12
Wash basin	1 ½	Wash basin	0.15
Bath	10	Wash basin with spray taps	0.04
Sink	3-5	Bath (private)	0.30
		Bath (public)	0.60
		Shower	0.12
Offices			
W.C. flushing cistern	2	Sink with 13mm taps	0.20
Wash basin(distributed use)	1 ½	Sink with 19mm taps	0.30
Wash basin (concentrated use)	3	Sink with 25mm taps	0.60
Schools and industrial buildings			
W.C. flushing cistern	2		
Wash basin	3		
Shower	3		
Public bath	22		

Equivalent length for frictional resistance

Copper/Plastic			Galvanized steel			
Nominal outside diameter (mm)	Meter run of pipe		Nominal outside diameter (mm)	Meter run of pipe		
	Elbow	Tee		Elbow	Bend	Tee
15	0.5	0.6	15	0.5	0.4	1.2
22	0.8	1.0	20	0.6	0.5	1.4
28	1.0	1.5	25	0.7	0.6	1.8
35	1.4	2.0	32	1.0	0.7	2.3
42	1.7	2.5	40	1.2	1.0	2.7
54	2.3	3.5	50	1.4	1.2	3.4
62	3.0	4.5	65	1.7	1.3	4.2
76	3.4	5.8	80	2.0	1.6	5.3
108	4.5	8.0	100	2.7	2.0	6.8



Loss of Heads in Pipes

Data Sheet 6

Sprinkler arrangements

S= design spacing of sprinkler on range pipes

{	Max. 4.6 m extra light hazard
	Max. 4.0 m ordinary hazard
	Max. 3.7 m extra high hazard

D= distance between rows of sprinklers

S x D =

{	21 m ² or less, extra light hazard
	12 m ² or less, ordinary hazard
	9 m ² or less, extra high hazard

Classification of occupancies

Extra light hazard

Hospitals, hotels, libraries, museums, nursing homes, offices, prisons, schools, colleges

Ordinary hazard (Group I)

Butchers, breweries, cement works, cafes

Ordinary hazard (Group II)

Bakeries, chemical works (ordinary), engineering works, laundries, garages, potteries, shops

Ordinary hazard (Group III)

Aircraft factories (excluding hangars), boot and shoe factories, carpet factories, clothing factories, departmental stores, plastic factories, printing rooms, saw mills, warehouses

Group III (Special)

Cotton mills, distillers, film and television studios, match factories

Extra high hazard

Celluloid works, foam plastics and rubber factories, paint and varnish factories, wood and wood works, high piled storage risks, oil flammable liquid hazard

Index No:

Air conditioner Selection Form

Job Name:..... Date:.....

Location:..... Estimated by:.....

	Item	Quantity		Factor		BTU/hr
				90 *	95*	
1	Window exposed to Sun	N or E NW W NE & SW	sqft sqft sqft sqft	42 77 85 57	47 80 100 60	=
2	All windows not included in item 1		sqft	20	25	=
3	Wall exposed to Sun (wall considered in item 1)	Light construction Heavy construction	lnft lnft	60 40	70 50	=
4	All exterior walls not included in item 3		lnft	22	27	=
5	Partitions	All interior walls adjacent to an unconditioned spaces	lnft	20	30	=
6	Ceiling or Roof (use only one)	Ceiling with unconditioned space Ceiling with no insulation Attic space with insulation Flat roof with no insulation Ceiling below with insulation Roof no insulation	sqft sqft sqft sqft sqft sqft	1 8 5 7 3 14	3 10 3 8 3 16	=
7	Floor	Over unconditioned space	sqft	2	3	=
8	People	Including allowances for ventilation through unit	No x 1000		=
9	Light & Electrical equipment		W x 3.41		=
10	Doors or Arches continuously open to unconditioned space		Nos x 250		=
Total cooling load						=

*:- outside design condition of
1 BTU(British Thermal Unit)/hr=0.2931 Watt